

# Site Accessibility Evaluation



**Eastonville Road / Del Rio  
Road Pedestrian Ramp In  
PU19-0007**

**Eastonville Rd  
Peyton, CO 80831**

*Inspection Date: 11/17/2017  
Inspector: David Mejia*

**Prepared By**



**(719) 520 - 6866  
www.elpasoco.com**

**Eastonville and Del Rio Rd Intersection**

**Finding: 1**

No diagonal or corner curb ramps, sidewalks exists. ADA compliance for school zone.

2010 ADAS Section 406.3  
Where provided, curb ramp flares shall not be steeper than 1:10.

**Citation:**

2010 ADAS Section: 406.3

**As Built:**

No pedestrian ramp, curb nor sidewalk exist

**Recommendation:**

Design and construct curb ramp for accessible path of travel. See 2010 ADAS section 4.06 for specifications and compliance. Maximum running slope of 1:12 (8.33%) and maximum cross slope of 1:48 (2.08%). if provided, curb ramp flares shall not be steeper than 1:10 (10%)

**Notes:**

Corrective Action:



Finding 248593 Main Photo

