

Site Accessibility Evaluation



**Pedestrian Ramp on
Baptist Road and Struthers
Road
PU17-0087**

**785 W. Baptist Road
Colorado Springs, CO
80921**

Public Right of Way

***Inspection Date: 07/27/2017
Inspector: David Mejia***

Prepared By



**(719) 520 - 6866
www.elpasoco.com**

Baptist Road and Struthers Road Pedestrian Crosswalk Pushbutton

Finding: 1

The pushbutton is not accessible because there is not an accessible route adjacent to the clear floor space.

One full unobstructed side of the clear floor or ground space shall adjoin an accessible route or adjoin another clear floor or ground space. Clear floor or ground space may overlap an accessible route

2011 PROWAG Section R404.6

One full unobstructed side of a clear space shall adjoin a pedestrian access route or adjoin another clear space.

Citation:

2011 PROWAG Section: R404.6

As Built:

No access to the pedestrian crosswalk pushbutton

Recommendation:

Install an accessible route to allow access to the pedestrian crosswalk push-button and meet the recommended Approach Standard (305.6) of the 2010 ADA Standards.

Notes:

Corrective Action:



Finding 89501 Main Photo

Finding #1 Additional Finding Photos



Finding 89501 Additional Photo

CORRECTED